



| REINFORCING STEEL LEGEND | |
|--------------------------|------|
| 48" | A500 |
| 60" | A501 |
| 34" | A502 |

| INSIDE DIAMETER (X) OF PIPE (INCHES) | MINIMUM DEPTH - (FEET) | | |
|--------------------------------------|------------------------|-----------------------|-------------------|
| | CONCRETE PIPE | CORRUGATED METAL PIPE | POLYETHYLENE PIPE |
| 18 | 4.25 | 4.04 | 4.17 |
| 24 | 4.75 | 4.54 | 4.71 |
| 30 | 5.33 | 5.04 | 5.29 |

- DEPTH MEASUREMENT MADE FROM TOP OF GRATE TO OUTLET FLOW ELEVATION BASED ON INLET AND OUTLET PIPES BEING THE SAME DIAMETER, IF OUTLET PIPE IS GREATER ADJUSTMENT IN DEPTHS MUST BE MADE TO ACCOMMODATE THIS SITUATION.
- TO DETERMINE FLOOR OF CATCH BASIN ELEVATION, WHEN INLET AND OUTLET PIPES ARE THE SAME SIZE, ADD PIPE WALL THICKNESS PLUS 1.5" TO THE ABOVE MINIMUM DEPTHS.

| INSIDE DIAMETER (X) OF PIPE (INCHES) | DIAMETER OF CUT-OUT HOLES F & G - (INCHES) | | |
|--------------------------------------|--|-----------------------|-------------------|
| | CONCRETE PIPE | CORRUGATED METAL PIPE | POLYETHYLENE PIPE |
| 18 | 26 | 21 | 24 |
| 24 | 32 | 27 | 31 |
| 30 | 40 | 33 | 39 |

① TO BE USED IN FRONT AND BACK WALLS ONLY.

- ### GENERAL NOTES
- DRAWING TO BE USED FOR NO. 13 BRICK CATCH BASINS THAT ARE EIGHT FEET AND LESS IN DEPTH. SEE STANDARD DRAWINGS D-CB-13P AND D-CB-13S FOR DETAILS OF NO. 13 CONCRETE CATCH BASINS THAT ARE MORE THAN EIGHT FEET IN DEPTH.
 - CAST-IN-PLACE CONCRETE USED IN BRICK CATCH BASINS SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD SPECIFICATIONS, SECTION 611 AND/OR SPECIAL PROVISIONS.
 - THE CONTRACTOR MAY WITH PERMISSION FROM THE ENGINEER SUBSTITUTE PRECAST CATCH BASINS FOR CAST-IN-PLACE CATCH BASINS PROVIDED THAT ALL PRECAST ELEMENTS MEET ASTM M913 (CURRENT EDITION) UNLESS SUPERSEDED BY THIS DRAWING.
CONCRETE: $F_c = 4,000$ POUNDS PER SQUARE INCH AT 28 DAYS
REINFORCING STEEL: ASTM A615, $F_y = 60,000$ POUNDS PER SQUARE INCH
ALL REINFORCING IS TO BE INSTALLED AS DETAILED ON THIS DRAWING.
 - PRECAST CATCH BASIN UNITS USED FOR LIDS AND FLOORS WHICH ARE DAMAGED DURING SHIPMENT OR INSTALLATION WILL BE REJECTED. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPLACE DAMAGED CATCH BASIN UNITS AT HIS OWN EXPENSE.
 - APPROPRIATE SIZING AND LOCATION OF LIFTING DEVICES SHALL BE THE RESPONSIBILITY OF THE FABRICATOR TO ASSURE BALANCED HANDLING DURING INSTALLATION OF THE CATCH BASIN.
 - THE CONTRACTOR IS TO PATCH ALL LIFTING DEVICE HOLES AND PLACE A MINIMUM OF ONE (1) INCH OF COVER OVER THE HARDWARE OF THESE DEVICES ON BOTH TOP AND BOTTOM SURFACES.
 - INVERT ELEVATIONS ARE TO BE ADJUSTED AS DIRECTED BY THE ENGINEER IN ORDER TO ACCOMMODATE INLET AND OUTLET PIPES.
 - SEE STANDARD DRAWING D-CBB-13 FOR DETAILS REGARDING CAST IRON GRATES, FRAMES AND CURB INLETS.
 - PAYMENT FOR CATCH BASIN WILL BE MADE UNDER ITEM NUMBER 611-13.02 CATCH BASINS, TYPE 13, > 4'-8' DEPTH PER EACH.

- REV. 12-18-96: MODIFIED DRAWING NO. D-CB-12B BY CHANGING CURB IRON.
- REV. 12-31-96: REMOVED 0.5" PREMOLDED FIBER EXPANSION JOINT FROM SECTION "B-B". REMOVED OLD GENERAL NOTE ①. CHANGED LABEL OF LAST THREE GENERAL NOTES.
- REV. 4-15-97: CHANGED LABEL OF BASE SECTION.
- REV. 10-26-97: CHANGED MINIMUM DEPTH TABLE AND MODIFIED STEEL IN BASE SECTION.
- REV. 1-19-99: MODIFIED CATCH BASIN MINIMUM DEPTH TABLE.
- REV. 3-20-00: ADDED SPECIAL NOTE RESTRICTING USE OF NO. 13 CATCH BASINS TO RADIUS LESS THAN 25 FEET.
- REV. 5-27-01: CHANGED PAY ITEM IN GENERAL NOTE ①.
- REV. 7-29-02: CHANGED ASTM SPECIFICATION IN GENERAL NOTE ①.

SPECIAL NOTE
TO BE USED ON RADIUS LESS THAN 25 FEET. FOR RADIUS 25 FEET AND GREATER USE TYPE 12 CATCH BASIN.

□ MINOR REVISION -- FHWA APPROVAL NOT REQUIRED.