

REV. 5-27-01: CHANGED PAY ITEMS IN GENERAL NOTE J. ADDED CATCH BASIN MAXIMUM DEPTH NOTE.

CATCH BASIN MINIMUM DEPTH TABLE						
INSIDE DIAMETER (X) OF PIPE (INCHES)	MINIMUM DEPTH - (FEET)					
	CONCRETE PIPE	CORRUGATED METAL PIPE	POLYETHYLENE PIPE			
18	4.42	4.21	4.33			
24	4.92	4.71	4.88			
30	5.50	5.21	5.46			
36	6.04	5.75	5.96			

DEPTH MEASUREMENT MADE FROM TOP OF GRATE TO OUTLET FLOW ELEVATION BASED ON INLET AND OUTLET PIPES BEING THE SAME DIAMETER, IF OUTLET PIPE IS GREATER ADJUSTMENT IN DEPTHS MUST BE MADE TO ACCOMMODATE THIS SITUATION.

TO DETERMINE FLOOR OF CATCH BASIN ELEVATION, WHEN INLET AND OUTLET PIPES ARE THE SAME SIZE, ADD PIPE WALL THICKNESS PLUS 1.5" TO THE ABOVE MINIMUM DEPTHS.

CUT-OUT HOLES FOR INLET & OUTLET PIPES							
I NS I DE D I AME TE R	DIAMETER OF CUT-OUT HOLES F & G - (INCHES)						
(X) OF PIPE (INCHES)	CONCRETE PIPE	CORRUGATED METAL PIPE	POLYETHYLENE PIPE				
18	26	21	24				
24	32	27	31				
30	40	33	39				
36	47	40	45				

CUT-OUT HOLES FOR PRECAST STRUCTURES TO BE CORED OR FORMED IN ORDER TO OBTAIN A SMOOTH EDGED HOLE. SCORED OR ETCHED HOLES WITH REINFORCING STEEL LEFT UNCUT WILL NOT BE PERMITTED.

GENERAL NOTES

(A) DRAWING TO BE USED FOR ALL CAST-IN-PLACE NO. 45 CONCRETE CATCH BASINS AND ALL PRECAST NO. 45 CONCRETE

(B) CAST-IN-PLACE CONCRETE CATCH BASINS SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD SPECIFICATIONS,

THE CONTRACTOR MAY WITH PERMISSION FROM THE ENGINEER SUBSTITUTE PRECAST CATCH BASINS FOR CAST-IN-PLACE CATCH BASINS PROVIDED THAT ALL PRECAST ELEMENTS MEET ASTM M913 (CURRENT EDITION) UNLESS SUPERSEDED BY

REINFORCING STEEL: ASTM A615, F_y = 60,000 POUNDS PER SQUARE INCH

ALL REINFORCING IS TO BE INSTALLED AS DETAILED ON THIS DRAWING.

(D) PRECAST CATCH BASIN UNITS WHICH ARE DAMAGED DURING SHIPMENT OR INSTALLATION WILL BE REJECTED. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPLACE DAMAGED CATCH BASIN UNITS AT HIS OWN EXPENSE. ADDITIONAL REINFORCING STEEL NECESSARY ABOVE THE CORED OR FORMED CUT-OUT HOLES TO MAINTAIN THE INTEGRITY OF THE STRUCTURE DURING HANDLING AND PLACEMENT SHALL BE THE RESPONSIBILITY OF THE FABRICATOR. (F) APPROPRIATE SIZING AND LOCATION OF LIFTING DEVICES SHALL BE THE RESPONSIBILITY OF THE FABRICATOR TO ASSURE BALANCED HANDLING DURING INSTALLATION OF THE CATCH BASIN.

(G) THE CONTRACTOR IS TO PATCH ALL LIFTING DEVICE HOLES AND PLACE A MINIMUM OF ONE(1) INCH OF COVER OVER THE HARDWARE OF THESE DEVICES ON BOTH TOP AND BOTTOM SURFACES.

(H) INVERT ELEVATIONS ARE TO BE ADJUSTED AS DIRECTED BY THE ENGINEER IN ORDER TO ACCOMMODATE INLET AND

(I) SEE STANDARD DRAWING D-CBB-31 FOR DETAILS REGARDING CAST IRON GRATES, FRAMES AND CURB INLETS.

J) PAYMENT FOR CATCH BASIN WILL BE MADE UNDER ITEM NUMBERS 611-45.02 CATCH BASINS, TYPE 45, > 4′-8′

				MINO!	R REVISION FHWA
STEEL LEGE	IND				OVAL NOT REQUIRED.
то 1500 26°		26 "	Р H501	STATE DEPARTMENT	
	104 "			STAND	STANDARD 8' X 4' RECTANGULAR CONCRETE NO.45 CATCH BASIN (FOR USE UNDER CONCRETE MEDIAN BARRIER WALL)
	104″	35″	Н502	RECTANG NO.45 (FOR US	
				1-19-99	D-CB-45S