

- ☐ REV. 11-1-95: CHANGED TO METRIC
- REV. 10-26-96: MADE MINOR DIMENSIONING CORRECTIONS.
- REV. 12-18-96: REMOVED 13 mm PREMOLDED FIBER EXPANSION JOINT FROM SECTION "B-B". REMOVED OLD GENERAL NOTE (H.) CHANGED LABEL OF LAST THREE GENERAL NOTES.
- REV. 10-26-97: CHANGED MINIMUM DEPTH TABLE AND MODIFIED STEEL IN BASE SECTION.
- REV. 1-19-99: MODIFIED CATCH BASIN MINIMUM DEPTH TABLE.
- REV. 5-27-01: CHANGED PAY ITEMS IN GENERAL NOTE (). ADDED CATCH BASIN MAXIMUM DEPTH NOTE.
- REV. 7-29-02: CHANGED ASTM SPECIFICATION IN GENERAL NOTE ©.

## GENERAL NOTES

1420

H1601

H1602

(A) DRAWING TO BE USED FOR ALL CAST-IN-PLACE NO. 41 CONCRETE CATCH BASINS AND ALL PRECAST NO. 41 CONCRETE CATCH BASINS THAT ARE GREATER THAN 3.7 METER IN DEPTH. SEE STANDARD DRAWING DM-CB-41P FOR DETAILS OF PRECAST NO. 41 CONCRETE CATCH BASINS 3.7 METER AND LESS IN DEPTH.

REINFORCING STEEL LEGEND

A1600

A1601

A1602

A1603

H1600

- (B) CAST-IN-PLACE CONCRETE CATCH BASINS SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD SPECIFICATIONS, SECTION 611 AND/OR SPECIAL PROVISIONS.
- © THE CONTRACTOR MAY WITH PERMISSION FROM THE ENGINEER SUBSTITUTE PRECAST CATCH BASINS FOR CAST-IN-PLACE CATCH BASINS PROVIDED THAT ALL PRECAST ELEMENTS MEET ASTM M913 (CURRENT EDITION) UNLESS SUPERSEDED BY THIS DRAWING.

1220

865

VARIABLE

1525

- CONCRETE: f'c = 28 MPa AT 28 DAYS REINFORCING STEEL: ASTM A615M,  $F_{\Upsilon}$  = 415 MPa ALL REINFORCING IS TO BE INSTALLED AS DETAILED ON THIS DRAWING.
- PRECAST CATCH BASIN UNITS WHICH ARE DAMAGED DURING SHIPMENT OR INSTALLATION WILL BE REJECTED. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO REPLACE DAMAGED CATCH BASIN UNITS AT HIS OWN EXPENSE.
- (E) ADDITIONAL REINFORCING STEEL NECESSARY ABOVE THE CORED OR FORMED CUT-OUT HOLES TO MAINTAIN THE INTEGRITY OF THE STRUCTURE DURING HANDLING AND PLACEMENT SHALL BE THE RESPONSIBILITY OF THE FABRICATOR.
- (F) APPROPRIATE SIZING AND LOCATION OF LIFTING DEVICES SHALL BE THE RESPONSIBILITY OF THE FABRICATOR TO ASSURE BALANCED HANDLING DURING INSTALLATION OF THE CATCH BASIN.
- G THE CONTRACTOR IS TO PATCH ALL LIFTING DEVICE HOLES AND PLACE A MINIMUM OF 25 mm OF COVER OVER THE HARDWARE OF THESE DEVICES ON BOTH TOP AND BOTTOM SURFACES.
- $\stackrel{\textstyle \leftarrow}{\mathsf{H}}$  invert elevations are to be adjusted as directed by the engineer in order to accommodate inlet and outlet pipes.
- [] SEE STANDARD DRAWING DM-CBB-31 FOR DETAILS REGARDING CAST IRON GRATES, FRAMES AND CURB INLETS.
- PAYMENT FOR CATCH BASIN WILL BE MADE UNDER ITEM NUMBERS 611M41.02 CATCH BASINS, TYPE 41, > 1m-2m DEPTH THROUGH 611M41.06 CATCH BASINS, TYPE 41, > 5m-6m DEPTH PER EACH.

CATC	H BASIN MIN	IMUM DEPTH	TABLE		
INSIDE DIAMETER	MINIMUM DEPTH - (m)				
(X) OF PIPE (mm)	CONCRETE PIPE	CORRUGATED METAL PIPE	POLYETHYLENE PIPE		
450	1.30	1.23	1.27		
600	1.45	1.38	1.44		
750	1.62	1.54	1.61		

CATCH BASIN MAXIMUM DEPTH NOTE

MAXIMUM DEPTH FOR THIS STRUCTURE IS 6.1 m. WHEN DEPTH REQUIREMENTS EXCEED THIS DEPTH THE CONTRACTOR IS TO USE OTHER VERSIONS OF THE NO. 41 CATCH BASIN.

- 1 DEPTH MEASUREMENT MADE FROM TOP OF GRATE TO OUTLET FLOW ELEVATION BASED ON INLET AND OUTLET PIPES BEING THE SAME DIAMETER, IF OUTLET PIPE IS GREATER ADJUSTMENT IN DEPTHS MUST BE MADE TO ACCOMMODATE THIS SITUATION.
- 2 TO DETERMINE FLOOR OF CATCH BASIN ELEVATION, WHEN INLET AND OUTLET PIPES ARE THE SAME SIZE, ADD PIPE WALL THICKNESS PLUS 40 mm TO THE ABOVE MINIMUM DEPTHS.

CUT-OUT	HOLES FOR I	NLET & OUTL	ET PIPES		
INSIDE DIAMETER	DIAMETER OF CUT-OUT HOLES F & G - (MILLIMETERS)				
(X) OF PIPE (mm)	CONCRETE PIPE	CORRUGATED METAL PIPE	POLYETHYLENE PIPE		
450	660	535	610		
600	815	685	785		
750	1015	840	990		

- 1) CUT-OUT HOLES FOR PRECAST STRUCTURES TO BE CORED OR FORMED IN ORDER TO OBTAIN A SMOOTH EDGED HOLE. SCORED OR ETCHED HOLES WITH REINFORCING STEEL LEFT UNCUT WILL NOT BE PERMITTED.
- (2) TO BE USED IN FRONT AND BACK WALLS ONLY.



MINOR REVISION -- FHWA APPROVAL NOT REQUIRED.

STATE OF TENNESSEE DEPARTMENT OF TRANSPORTATION

STANDARD 1219 mm X 914 mm RECTANGULAR CONCRETE NO. 41 CATCH BASIN (FOR USE UNDER CONCRETE MEDIAN BARRIER WALL)

11-1-95

DM-CB-41S